

No. Fail: JBPM/IP/RNP:700-7/2/16-128 (27)  
(PEMBAHARUAN KEDUA BELAS)

# SIJIL PEPASANGAN KESELAMATAN KEBAKARAN

APPROVAL CERTIFICATE

Jabatan Bomba dan Penyelamat Malaysia  
dengan ini memperakukan  
Fire and Rescue Department of Malaysia  
hereby certify

**FIRE RESISTANT CABLE**  
**'TONN CABLE' CWZ**


Berdasarkan Piawaian  
Complying with

**BS 6387:2013 (CWZ)**

**Syarikat Berdaftar**  
Registered company

**TONN CABLE SDN BHD (593174-V)**  
**Lot 1 (PT54) Jalan Perusahaan 5,**  
**Kawasan Perusahaan Beranang,**  
**43700 Beranang,**  
**Selangor DE.**

Tempoh sah perakuan: **11/12/2023 hingga 10/12/2025**

  
**(KAMARULZAMAN MALIK ABDULLAH)**  
Pengarah  
Bahagian Perancangan dan Penyelidikan,  
b.p. Ketua Pengarah  
Jabatan Bomba dan Penyelamat Malaysia.

Tarikh: 11 September 2023



CERTIFIED TO ISO 9001:2015  
CERT. NO QMS 02101



CERTIFIED TO ISO 37001:2016  
CERT. NO ABMS 00216



PEMENANG ANUGERAH  
EMAS AIGA 2022

**\*\* Peringatan:**

Sila patuhi sepenuhnya syarat-syarat dan had kegunaan seperti dalam Lampiran A1



No. Fail: **JBPM/IP/RNP:700-7/2/16-128 (27)**

**LAMPIRAN A1**

No.Siri: **BB/CABLE/864/2011 (P12)**

---

Jenis Alat Kelengkapan	: <b>FIRE RESISTANT CABLE</b>
Model & Spesifikasi	: <b>TONN CABLE/1 CORE/NON-AMOURED (1.5mm<sup>2</sup>-630mm<sup>2</sup>) TONN CABLE/2/3/4 CORES/NON AMOURED (1.5mm<sup>2</sup>- 240mm<sup>2</sup>) TONN CABLE/2/3/4 CORES/AMOURED(1.5mm<sup>2</sup>-630mm<sup>2</sup>) TONN CABLE/1 CORE/NON-AMOURED(1.5mm<sup>2</sup>-95mm<sup>2</sup>) (MICA TAPE/LSHF) TONN CABLE/1 CORE/NON-AMOURED(1.5mm<sup>2</sup>-630mm<sup>2</sup>) (MICA TAPE/XLPE/PVC-FR) TONN CABLE/1 CORE/NON-AMOURED(1.5mm<sup>2</sup>-630mm<sup>2</sup>) (MICA TAPE/XL-LSHF/LSHF)</b>
Nama & Alamat Pengeluar	: <b>TONN CABLE SDN BHD</b>
Tahap Rintangan Api	: <b>KATEGORI C, W, Z</b>
No. Laporan ujian/Tarikh	: <b>SIRIM 2010EL0713, SIRIM 2010EL0716, 2010EL0718, 2011EL0536, 2012EL1549, 2021EA1207/2021EA1208/ 2021EA1209/2021EA1210/2021EA1211/2021EA1212 (17/11/2021)</b>
Skim Persijilan Barangan	: <b>SIRIM QAS INT. NO. PT049504, NO. SIRI 080716 (SAH SEHINGGA 10/12/2023)</b>
Had Kegunaan	: <b>PEMASANGAN HENDAKLAH MEMATUHI SPESIFIKASI UJIAN, UBBL 1984 DAN SYARAT-SYARAT TAMBAHAN SEPERTI DI LAMPIRAN A2 &amp; A3.</b>

---

Tempoh sah perakuan: **11/12/2023 hingga 10/12/2025**

