



SIRIM QAS INTERNATIONAL SDN. BHD.

(No. Syarikat 199601037981(410334-X))

1, Persiaran Dato' Menteri, Seksyen 2, Peti Surat 7035, 40700 Shah Alam, Selangor Darul Ehsan, Malaysia
Tel : 603-5544 6000 Emel : cserviceqas@sirim.my www.sirim-qas.com.my

File No : P5-004532
Licence No : PT049506

Date : 20/12/2024

TONN CABLE SDN BHD
LOT 1 (PT 54), JALAN PERUSAHAAN 5
KAWASAN PERUSAHAAN BERANANG
43700 BERANANG
SELANGOR, MALAYSIA

Attn : NURASHIKIN BINTI MOHAMMED NOR

Tel No : 03-87669888

Fax No : 03-87668111

Dear Sir/Madam,

Product Certification Licence

Product : FLAME RETARDANT CABLES - CATEGORY A
Standard : IEC 60332-3-22 : 2009

With regards to your request for new/renewal/changes of licence(s) under the SIRIM Product Certification Licence scheme, enclosed please find the copy of the licence(s) and the certification report(s) for your safe keeping.

For enquiry, please contact

Officer Name : MUHAMMAD AZHAR MD. ARIS
Contact No : 6017-3039266
Email : azharma@sirim.my

Thank you.

This is a computer generated document. No signature is required.

LESEN PENSIJILAN BARANGAN

Product Certification Licence



SIRIM

SIRIM QAS International Sdn. Bhd. dengan ini menganugerahkan kepada
SIRIM QAS International Sdn. Bhd. hereby grants to

**TONN CABLE SDN BHD
LOT 1 (PT 54), JALAN PERUSAHAAN 5
KAWASAN PERUSAHAAN BERANANG
43700 BERANANG
SELANGOR, MALAYSIA**

Lesen untuk menggunakan Tanda Pensijilan di atas barangan
a licence to use the Certification Mark on

FLAME RETARDANT CABLES - CATEGORY A

Please refer to detail in the SCHEDULE

sebagai mematuhi keperluan
as complying with

IEC 60332-3-22 : 2009



Nur Fadhilah binti Muhammad
Ketua Pegawai Eksekutif
Chief Executive Officer
SIRIM QAS International Sdn. Bhd.



SCHEDULE

TONN CABLE SDN BHD



SIRIM

Trade Mark	: TONN CABLE
Model	: MICA-LAYERED, MINERAL FILLED LSHF INSULATED, NON-ARMOURED, SINGLE-CORE, STRANDED CIRCULAR PLAIN ANNEALED COPPER CONDUCTOR (1.5, 2.5, 4, 6, 10) SQ. MM.
Rating	: 600/1000V
Trade Mark	: TONN CABLE
Model	: MICA-LAYERED, XLPE-INSULATED, PVC-SHEATHED, NON-ARMOURED, SINGLE-CORE, STRANDED CIRCULAR PLAIN ANNEALED COPPER CONDUCTOR (1.5, 2.5, 4, 6, 10, 16, 25, 35, 50, 70, 95, 120, 150, 185, 240, 300, 400, 500, 630) SQ. MM.
Rating	: 600/1000V
Trade Mark	: TONN CABLE
Model	: MICA-LAYERED, MINERAL FILLED XL-LSHF INSULATED, MINERAL FILLED LSHF-SHEATHED, NON-ARMOURED, SINGLE-CORE, STRANDED CIRCULAR PLAIN ANNEALED COPPER CONDUCTOR (1.5, 2.5, 4, 6, 10, 16, 25, 35, 50, 70, 95, 120, 150, 185, 240, 300, 400, 500, 630) SQ. MM.
Rating	: 600/1000V
Trade Mark	: TONN CABLE
Model	: MICA-LAYERED, MINERAL FILLED XL-LSHF INSULATED, MINERAL FILLED LSHF SHEATHED, NON-ARMOURED, STRANDED PLAIN ANNEALED COPPER CONDUCTOR. 2-CORE, 3-CORE, 4-CORE (1.5, 2.5, 4, 6, 10, 16, 25, 35, 50, 70, 95, 120, 150, 185, 240) SQ. MM.
Rating	: 600/1000V
Trade Mark	: TONN CABLE
Model	: MICA-LAYERED, MINERAL FILLED XL-LSHF INSULATED, MINERAL FILLED LSHF SHEATHED, ARMOURED, STRANDED PLAIN ANNEALED COPPER CONDUCTOR. 2-CORE, 3-CORE, 4-CORE (1.5, 2.5, 4, 6, 10, 16, 25, 35, 50, 70, 95, 120, 150, 185, 240) SQ. MM.
Rating	: 600/1000V
Trade Mark	: TONN CABLE
Model	: MICA-LAYERED, PVC-INSULATED, NON-ARMOURED, SINGLE-CORE, STRANDED CIRCULAR PLAIN ANNEALED COPPER CONDUCTOR (1.5, 2.5, 4, 6, 10, 16, 25, 35, 50, 70, 95) SQ. MM.
Rating	: 600/1000V

End of page

SIRIM QAS International Sdn. Bhd.
(No. Syarikat 199601037981(410334-X))

1, Persiaran Dato' Menteri
Seksyen 2, Peti Surat 7035
40700 Shah Alam
Selangor Darul Ehsan
MALAYSIA.

Tel : 603-5544 6000
Emel : cserviceqas@sirim.my

<https://www.sirim-qas.com.my>
<https://www.malaysiancertified.com.my>

Tarikh Mula Pensijilan : 10 December 2010

Certified Since

Sah Sehingga : 10 December 2025

Valid Until

Tarikh Dikeluarkan : 20 December 2024

Issue Date

No Siri : 106099

Serial No

Lesen ini dianugerahkan tertakluk kepada syarat-syarat Perjanjian Pensijilan Barangan SIRIM QAS International Sdn. Bhd.
This Licence is granted subject to the provisions of the Product Certification Agreement of SIRIM QAS International Sdn. Bhd.